



Mitsubishi Electric Cooling & Heating

1340 Satellite Blvd. Suwanee, GA 30024

Phone: 678-376-2900.

[www.facebook.com/mehvac](http://www.facebook.com/mehvac) | [www.twitter.com/mitsubishihvac](https://twitter.com/mitsubishihvac) |

[www.youtube.com/mitsubishihvac](http://www.youtube.com/mitsubishihvac)

Subject: **Additives to Mitsubishi HVAC Products**

To Whom It May Concern:

Mitsubishi Electric Cooling & Heating strongly recommends against using any additive sealer in our HVAC systems due to the possibilities of causing restrictions. In fact, any other additive whether it is a sealer, dyes, etc. could potentially cause problems with refrigerant flow in our system and also is ***not recommended***.

Should any problems that may arise due to these additives having been added to the system could void the manufacturer's warranty.

If you have questions or concerns, please call 1-800-433-4822 to speak with a Technical Service Advisor or contact your Area Service Manager.

Sincerely,

Mitsubishi Electric Cooling & Heating